

RESIDENT'S NAME _____ ADDRESS _____

BLOCK _____ LOT _____ INSTALLATION DATE _____

CONTRACTOR'S NAME _____ ADDRESS _____

CHECK TYPE OF POOL: NEW _____ OVERFLOW _____ PERMIT NO _____

HOMEOWNER'S SIGNATURE _____ SIGNATURE OF APPLICANT _____

(DRAW DIAGRAM OF LOCATION AND SIZE OF POOL ON REVERSE SIDE OF THIS FORM)
COMPLETE THIS SECTION AFTER WORK IS COMPLETED

I, _____ certify that the work was performed in accordance with the approved plans of Permit No. _____ and the Nassau County Department of Health Regulations.

Sworn to before me this _____ day of _____ 201_____

Notary Public, Nassau County, NY

(signature)

INCORPORATED VILLAGE OF MUNSEY PARK
1777 NORTHERN BLVD.
MANHASSET, NY 11030
516-365-7790

CESSPOOL PERMIT APPLICATION

1. All new installations and replacements shall consist of a septic tank and sanitary rings installed in accordance with the Nassau County Department of Health Standards.
2. Septic tanks shall be sized in accordance with the number of bedrooms contained within the dwelling unit as follows: 4
bedrooms 1,000 gals minimum
5 bedrooms 1,250 gals minimum
6 bedrooms 1,500 gals minimum
3. The following minimum distances shall be maintained from any septic tank:
Property Line 10 feet
Leaching Pool 5 feet

Water Service Line 10 feet
Building Wall 10 feet
Drywell 20 feet
4. The following minimum distances shall be maintained from any sanitary ring (leaching pool):
Septic Tank 5 feet
Leaching Pool 10 feet
Drywell 20 feet
Property Line 10 feet
Building Wall 20 feet
5. A permit must be obtained from the Village Clerk, **BEFORE BEGINNING CONSTRUCTION** of a new or replacement system.
6. Application must be accompanied by a diagram of the proposed size and location of the components and Certificate of Liability, Disability & Compensation Insurance, Nassau County License fee of \$250 plus deposit of \$1000 or submit a bond to cover damages caused by applicant.
7. Systems shall be located in the front yard. House traps connecting to the cesspool must be located as close to the entrance wall as possible.
8. Systems shall be precast type, eight feet (8') in diameter, with precast dome. All underground piping shall comply with the Plumbing Code of New York State.
9. The system shall be installed to a depth necessary to encounter coarse sand stratum, subject to the approval of the inspector.
10. The outside walls of the septic rings (leaching rings) shall have at least eighteen inches (18") backfill of coarse gravel, broken stone, or coarse sand.
11. The access cover shall be a maximum of two feet six inches (2' 6") a minimum of two feet (2') below grade. The cesspool opening shall be fitted with a concrete cover not exceeding three feet (3') in diameter and shall be at least four inches (4") thick.
12. No cesspool or surface basin shall be installed until the excavation and plan of installation has been inspected and approved by the inspector.
13. All cesspools, leaching pools, septic tanks, etc. which are abandoned or discontinued shall be backfilled with clean sand or gravel.